

## **Submittal Data Sheet**

Outdoor Unit Model#: ACIQ-27Z-HH-M4C\*

Multi Zone Heat Pump System		
Location:	Approval:	
Engineer:	Date:	
Submitted to:	Construction:	
Submitted by:	Unit #:	
Reference:	Drawing #:	



EFFICIENCY RATINGS			
С	ooling	Hea	iting
SEER2	23.0	HSPF2-4	10.5
EER2	12.5	COP	3.8

COOLING PERFORMANCE Cooling (Btu/hr)		
Min/Max Capacity	7200~37000	
Moisture Removal (L/h)	0.8	
Standard Operating Range (°F/°C)	-22~122 / (-30~50)	
Rated Cooling Conditions:	Indoor: 80°F DB/67°F WB	
	Outdoor: 95°F DB/75°F WB	


HEATING PERFORMANCE			
Heating (Btu/hr)			
1. @ 47°F Rated	27000		
1. @ 47°F Min/Max Capacity	8400~36000		
2. @ 17°F Rated (H32)	25000		
3. @ 5°F Rated: Capacity / COP (H42)	27000 / 2		
3. @ 5°F Max: Capacity	27000		
Standard Operating Range (°F/°C)	-22~75 / (-30~24)		
1. Conditions:	Indoor: 70°F DB/60°F WB		
	Outdoor: 47°F DB/43°F WB		
2. Conditions:	Indoor: 70°F DB/60°F WB		
	Outdoor: 17°F DB/15°F WB		
3. Conditions	Indoor: 70°F DB/60°F WB		
	Outdoor: 5°F DB/5°F WB		

	OUTDOOR UNIT SPECIFICATIONS		
Compressor Type		ROTARY	
Comp	ressor Model	KTF310D43UMT	
R	efrigerant	R454B	
Refrigerar	nt Oil Charge (mL)	1000	
Ref	rigerant Oil	VG74	
Outdoor Ai	r Flow (Max) (CFM)	2148	
Outdoor N	loise Level (dBA)	61	
Dimension	inch	37.24 x 16.14 x 31.89	
(W×D×H)	mm	946 × 410 × 810	
Package (W×D×H)	inch	42.91 x 19.68 x 34.84	
	mm	1090 × 500 × 885	
Net/Gross Weight	lbs	168.43 / 179.67	
	kg	76.4 / 81.5	


ELECTRICAL SPECIFICATIONS	
Power Supply	208/230V,60Hz,1Ph
System MCA	30
Connection Wiring	AWG 14-4
System MOP	35
Compressor RLA	17
Outdoor Fan Motor RLA	1.3
Outdoor Fan Motor W	120
Indoor Fan Motor RLA	1
Indoor Fan Motor W	1
System Power Input @ Cooling (W)	2125 / (500 ~ 3620)
System Power Input @ Heating (W)	2082 / (500 ~3400)
MCA: Min. circuit amps (A)	MOP: Max. overcurrent protection (A)
RLA: Rated load amps (A)	W: Fan motor rated output (W)

REFRIGERANT PIPING SPECIFICATIONS	
Liquid Size	4 x 6.35mm (4 x 1/4in)
Gas Size	3 x 9.52mm + 1 x 12.7 mm (3 x 3/8 in + 1 x 1/2in)
Max. Piping Length for all rooms (ft/m)	262.4 / (80)
Max. Piping Length for one IDU (ft/m)	114.8 / (35)
Max. Height Difference of IDU and ODU (ft/m)	49.2 / (15)
Refrigerant Pre-charged Amount (oz/kg)	120.63 / (3.42)
Refrigearant Precharge Length (ft/m)	24.6 (7.5) x 4
Additional Charge of Refrigerant (Φ6.35 (1/4") liquid pipe) ((oz/ft)/(g/m))	0.16 / (15)
Additional Charge of Refrigerant (Φ9.52 (3/8") liquid pipe) ((oz/ft)/(g/m))	0.32 (30)
Connection Method	Flared

<sup>\*</sup>System performance figures & efficiency ratings above achieved by testing condenser with (1) 9K & (3) 6K Non-ducted air handlers



## **Installation Instructions**



Meets all spatial requirements shown in Installation Clearance Requirements above.